

City of Wellington, KS

CONSUMER CONFIDENCE REPORT - 2019

Covering Calendar Year 2018

This brochure is a snapshot of the quality of the water that we provided last year. We are committed to providing you with this information because informed customers are our best allies. It's important that customers be aware of the efforts that are made continually to improve their water system. To learn more, please attend any of the regularly scheduled City Council meetings, which are held on the 1st and 3rd Tuesday of every month at 6:30pm at the City Administration Center. For more information, please contact Mike Clift, Water Production supervisor (620-434-5353), or visit our web site www.cityofwellington.net.

This report is divided into five basic sections: Source Water, Water Treatment, Water Distribution System, Message from EPA and Water Quality Data.

Source Water

Your water is treated to remove several contaminants and a disinfectant is added to protect you against microbial contaminants. The Safe Drinking Water Act (SDWA) required states to develop a Source Water Assessment (SWA) for each public water supply that treats and distributes raw source water in order to identify potential contamination sources. The state has completed an assessment of our source water. For results of the assessment, please contact us or view on-line at: <http://www.kdheks.gov/nps/swap/SWreports.html>.

The City of Wellington treated and sent approximately 406 million gallons of water to town in 2018. Of this total, about 78% came from Wellington Lake and about 22% came from our 9 groundwater wells.

Water Treatment

The City's Water Treatment Plant uses hydrated lime and aluminum sulfate in the treatment process. Hydrofluorosilic acid (fluoride) is added to the treated water and chlorine is used for disinfection.

Water Distribution System

- The Water Plant has four vertical turbine pumps that pump the treated water from the Treatment Plant to the City's million gallon elevated water tower near the intersection of 15th and "A" Streets.

- The distribution system pressure, when the Plant is pumping the treated water to town, is around 60 psi. When the Plant is not pumping the treated water to town, the system pressure is reliant on the elevation of the treated water in the City's elevation water towers. Depending on a variety of factors such as distance from the towers, distribution line size and relative elevation, the system pressure varies from approximately 40 psi to approximately 60 psi.
- There is a 1.8 million gallon underground clearwell located at the Treatment Plant.

The City of Wellington provided treated water to the following public water suppliers in 2018:

RWD #1	9,834,000 gallons	2.42% of total
RWD #2	14,663,000 gallons	3.61% of total
RWD #3	2,836,000 gallons	0.69% of total
City of Mayfield	1,789,000 gallons	0.44% of total

The City also supplies treated water to the Kansas Turnpike Authority's Belle Plaine Service Area.

Message from EPA

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as those with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health

effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally, occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water before we treat it include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife

Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming

Pesticides and herbicides may come from a variety of sources such as storm water run-off, agriculture, and residential users.

Radioactive contaminants, which can be naturally occurring or the result of mining activity

Organic contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and also come from gas stations, urban storm water run-off, and septic systems.

In order to ensure that tap water is safe to drink, EPA prescribes regulations, which limits the amount of certain contaminants in water provided by public water systems, we treat our water according to EPA's regulations. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Our water system tested a minimum of 9 samples per month in accordance with the Total Coliform Rule for microbiological contaminants. Coliform bacteria are usually harmless, but their presences in water can be an indication of disease-causing bacteria. When coliform bacteria are found, special follow-up tests are done to determine if harmful bacteria are present in the water supply. If this limit is exceeded, the water supplier must notify the public by newspaper, television or radio.

Water Quality Data

The tables following below list all of the drinking water contaminants, which were detected during the 2018 calendar year. The presence of these contaminants does not necessarily indicate the water poses a health risk. Unless noted, the data presented in this table is from the testing done January 1- December 31, 2018. The state requires us

to monitor for certain contaminants less than once per year because the concentrations of these

Contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old. **The bottom line is that the water that is provided to you is safe.**

Terms & Abbreviations

Maximum Contaminant Level Goal (MCLG): the "Goal" is the level of a contaminant in drinking water below which there is no known or expected risk to human health. MCLGs allow for a margin of safety.

Maximum Contaminant Level (MCL): the "Maximum Allowed" MCL is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Secondary Maximum Contaminant Level (SMCL): recommended level for a contaminant that is not regulated and has no MCL.

Action Level (AL): the concentration of a contaminant that, if exceeded, triggers treatment or other requirements.

Treatment Technique (TT): a required process intended to reduce levels of a contaminant in drinking water.

Maximum Residual Disinfectant Level (MRDL): the highest level of a disinfectant allowed in drinking water.

There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Non-Detects (ND): lab analysis indicates that the contaminant is not present.

Parts per Million (ppm) or milligrams per liter (mg/l)

Parts per Billion (ppb) or micrograms per liter (µg/l)

Picocuries per Liter (pCi/L): a measure of the radioactivity in water.

Millirems per Year (mrem/yr.): measure of radiation absorbed by the body.

Monitoring Period Average (MPA): An average of sample results obtained during a defined time frame, common examples of monitoring periods are monthly, quarterly and yearly.

Nephelometric Turbidity Unit (NTU): a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person. Turbidity is not regulated for groundwater systems.

Running Annual Average (RAA): An average of sample results obtained over the most current 12 months and used to determine compliance with MCLs.

Locational running annual average (LRAA): Average of sample analytical results for samples taken at a particular

monitoring location during the previous four calendar quarters.

Testing Results for: City of Wellington

Regulated Contaminants	Collection Date	Your Highest Value	Range (low/high h)	Unit	MCL	MCLG	Typical Source
ARSENIC	5/7/2018	1.6	1.6	ppb	10	0	Erosion of natural deposits
ATRAZINE	6/18/2018	0.36	0.36	ppb	3	3	Runoff from herbicide used on row crops
BARIUM	5/7/2018	0.054	0.054	ppm	2	2	Discharge from metal refineries
FLUORIDE	5/7/2018	1.2	0.71 - 1.2	ppm	4	4	Natural deposits; water additive which promotes strong teeth
NITRATE	5/7/2018	2.5	1.7 - 2.5	ppm	10	10	Runoff from fertilizer use
SELENIUM	5/7/2018	3.3	3.3	ppb	50	50	Erosion of natural deposits

Disinfection Byproducts	Monitoring Period	Your Highest RAA	Range (low/high h)	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)	2018	29	17 - 33	ppb	60	0	By-product of drinking water disinfection
TOTAL TRIHALOMETHANES (TTHMs)	2018	71	49 - 85	ppb	80	0	By-product of drinking water chlorination

Lead and Copper	Monitoring Period	90 th Percentile	Range (low/high)	Unit	AL	Sites Over AL	Typical Source
COPPER, FREE	2016 - 2018	0.04	0.0012 - 0.066	ppm	1.3	0	Corrosion of household plumbing
LEAD	2016 - 2018	2.7	1.2 - 10	ppb	15	0	Corrosion of household plumbing

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Total Organic Carbon Lowest Month for Removal	Number of Samples	Actual Removal Ratio	Required Removal Ratio	Lowest Monthly Removal Ratio
12/1/2018 - 12/31/2018	12	1.48	1.0 RATIO	0.90

Please Note: Because of sampling schedules, results may be older than 1 year.

Secondary Contaminants-Non Health Based Contaminants-No Federal Maximum Contaminant Level (MCL) Established.	Collection Date	Highest Value	Range (low/high)	Unit	SMCL
ALKALINITY, TOTAL	5/7/2018	46	46	MG/L	300
ALUMINUM	5/7/2018	0.3	0.3	MG/L	0.05
CALCIUM	5/7/2018	35	35	MG/L	200
CHLORIDE	5/7/2018	87	87	MG/L	250
CONDUCTIVITY @ 25 C UMHOS/CM	5/7/2018	670	670	UMHO/CM	1500
CORROSIVITY	5/7/2018	-0.89	-0.89	LANG	0
HARDNESS, TOTAL (AS CAC03)	5/7/2018	180	180	MG/L	400
MAGNESIUM	5/7/2018	22	22	MG/L	150
METOLACHLOR	6/18/2018	0.31	0.31	ppb	
PH	5/7/2018	7.5	7.5	PH	8.5
PHOSPHORUS, TOTAL	5/7/2018	0.31	0.31	MG/L	5
POTASSIUM	5/7/2018	7.1	7.1	MG/L	100
SILICA	5/7/2018	4.1	4.1	MG/L	50
SODIUM	5/7/2018	53	53	MG/L	100
SULFATE	5/7/2018	110	110	MG/L	250
TDS	5/10/2017	300	300	MG/L	500
ZINC	5/7/2018	0.027	0.027	MG/L	5

During the 2018 calendar year, we had no violation(s) of drinking water regulation.

Additional Required Health Effects Language:

Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

Total organic carbon (TOC) has no health effects. However, total organic carbon provides a medium for the formation of disinfection byproducts. These byproducts include trihalomethanes (THMs) and haloacetic acids (HAAs). Drinking water containing these byproducts in excess of the MCL may lead to adverse health effects, liver or kidney problems, or nervous system effects, and may lead to an increased risk of getting cancer.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

For additional information, please contact Mike Clift, at 620- 434- 5353.

Notice is being sent to you by City of Wellington, State Water System ID# Y0500, July 1, 2019

**City of Wellington, Kansas
317 South Washington
Wellington, Kansas 67152**